

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K110101

Building Name: MSB

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

*Reduce*

Inspected By: Bob Brown

Date: 1-25-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K110201

Building Name: Police Station

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Brad Brown

Date: 1-25-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K114101

Building Name: Water Plant #2

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Inspected By: Brend Brown

Date: 1-11-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K17803

Building Name: TRAIN DEPOT Pavilion

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Bruce Brown Date: 1-10-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K116301

Building Name: Train Depot

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: BRAD BROWN

Date: 1-10-11

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K 116401

Building Name: Court House

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Brad Brown Date: 1-10-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K116101

Building Name: O.F. Edwards

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Brad Brown

Date: 1-10-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K113 901

Building Name: City Hall

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does elevator provide audible signals?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Bruce Brown

Date: 1-10-12



**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K115101

Building Name: Station # 5

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Brad Brown

Date: 1-4-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K13601

Building Name: Station #4

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> <i>change</i>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> <i>Need remodeling for AOA</i>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Dud Daw

Date: 1-4-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K 111201

Building Name: Headquarters

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

*grab bars need.*

Inspected By: Bud Burn

Date: 1-4-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: 110301

Building Name: Waste water

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Just bathroom
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Bud Brown

Date: 1-4-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K 113902

Building Name: Planning & Zoning

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> <i>Back door</i>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Brad B. [Signature]

Date: 1-4-12

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K111107

Building Name: Fleet

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A	
<b>Building Access</b>				
• Are 96" wide parking spaces designated with a 60" access aisle?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Need
• Are parking spaces near main building entrance?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the door handle easy to grasp?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Change
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Building Corridors</b>				
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Do obstacles (phones, fountains) protrude no more than 4"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<b>Restrooms</b>				
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Build New restroom ADA
• Do doors have lever handles?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Do restroom entrance doors have at least 32" wide clearance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Are stall doors at least 32" wide?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Are grab bars provided in toilet stalls?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Are sink handles easily reached and used?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Personnel Office</b>				
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Inspected By: Brad Brown

Date: 12-29-11

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K110316

Building Name: Adman

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Brad Bunn

Date: 12-29-11

**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K116402

Building Name: Weldon Center

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A
<b>Building Access</b>			
• Are 96" wide parking spaces designated with a 60" access aisle?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are parking spaces near main building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is there a "drop off" zone at the building entrance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the gradient from parking to building entrance 1:12 or less?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are other than revolving doors available?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Building Corridors</b>			
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do obstacles (phones, fountains) protrude no more than 4"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator controls no higher than 48"?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are elevator markings in Braille?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Does elevator provide audible signals?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Restrooms</b>			
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Do doors have lever handles?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> <i>EX</i>
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are stall doors at least 32" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are grab bars provided in toilet stalls?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are sink handles easily reached and used?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Are soap dispensers and towels no more than 48" from the floor?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Personnel Office</b>			
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the door threshold no more than 1/2" high?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
• Is the path of travel between furniture wide enough for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Inspected By: Buddy Brown Date: 12-28-11

*Both doors need to be adjusted!*



**City of Kingsland  
"QUICK LOOK" BARRIERS CHECKLIST**

Location ID: K111501

Building Name: Public Works

This checklist is designed to give a quick appraisal of potential problem areas for accessibility. For detailed review standards, you may refer to federal ADA Accessibility Guidelines (ADAAG), state or local laws and regulations.

	YES	NO	N/A	
<b>Building Access</b>				
• Are 96" wide parking spaces designated with a 60" access aisle?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	No handicap spot
• Are parking spaces near main building entrance?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Is there a "drop off" zone at the building entrance?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Need spots + ramps
• Is the gradient from parking to building entrance 1:12 or less?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Does the entrance doorway have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the door threshold no more than 1/2" high?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
• Is the door handle easy to grasp?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Are the doors easy to open (building entrance maximum 8.5 lbs. pressure, all internal doors 5 lbs. max.)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Are other than revolving doors available?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<b>Building Corridors</b>				
• Is path of travel free of obstruction and at least 36" wide?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is floor surface firm and slip resistant?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Do obstacles (phones, fountains) protrude no more than 4"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Are elevator controls no higher than 48"?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Are elevator markings in Braille?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Does elevator provide audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Elevator interior provides minimum 51" turning area for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
<b>Restrooms</b>				
• Are restrooms near building entrance or personnel office?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Do doors have lever handles?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	change
• Do restroom entrance doors have at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is restroom large enough for wheelchair turnaround (51" minimum)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Door swing
• Are stall doors at least 32" wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
• Are grab bars provided in toilet stalls?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Install
• Are sinks at least 30" high with room for a wheelchair to roll under?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	change
• Are sink handles easily reached and used?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	change
• Are soap dispensers and towels no more than 48" from the floor?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lower
<b>Personnel Office</b>				
• Do doors provide at least 32" wide clearance?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the door easy to open? (max. 5 lbs. pressure)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
• Is the door threshold no more than 1/2" high?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Ramp.
• Is the path of travel between furniture wide enough for wheelchairs?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Inspected By: Ron Knux

Date: Dec 16, 11